



Note: The methods and data presented here are intended for use by the designer to estimate the power requirement for the oxygen demand using AIRE-O2 aeration equipment. This method is not intended to cover every application. Questions can be answered by contacting Newterra at 952-448-6789

Project Name:	Red Lake
Project Number:	2303140
Location:	MN USA
Unit Process:	Lagoon
Prepared by:	BFA

Input Data (Blue Cells)

Description

1	Flowrate =	0.146	MGD		Input flowrate
2	Volume =	26.00	MG		Input volume
3	BOD in =	200	mg/l	*Assumed Value Medium Strength Domestic Waste	Influent BOD
4	BOD out =		mg/l		Design output BOD
5	NH ₄ -N =	20	mg/l	*Assumed Value Medium Strength Domestic Waste	Design ammonia or TKN removal
6	Other =		mg/l		
7	BOD net =	200.0	mg/l		line 7 = (line 3) - (line 4)
8	BOD net =	243.5	lb/day		line 8 = (line 7) x (line 1)/1000
9	NH ₄ -N net =	24.4	lb/day		line 9 = (line 5) x (line 1)/1000
10	Other =	0.0	lb/day		line 10 = (line 6) x (line 1)/1000

ASSUMPTIONS

11	O ₂ : BOD =	1.5	lb O ₂ / lb BOD	Typically varies between 1 and 2
12	O ₂ : NH ₃ -N=	4.6	lb O ₂ / lb NH ₄ -N	Typical value is 4.6
13	O ₂ : Other =		lb O ₂ / lb Other	Depends on species

O₂ REQUIREMENT UNDER FIELD CONDITIONS (AOR)

14	O ₂ for BOD =	365.3	lb O ₂ / day	line 14 = (line 11) x (line 8)
15	O ₂ for NH ₄ -N =	112.0	lb O ₂ / day	line 15 = (line 12) x (line 9)
16	O ₂ for Other =	0.0	lb O ₂ / day	line 16 = (line 13) x (line 10)
17	AOR =	477.3	lb O ₂ / day	line 17 = (line 14) + (line 15) + (line 16)
18	AOR =	19.9	lb O ₂ / hour	line 18 = (line 17) / (24)

CORRECTION FACTORS TO DETERMINE O₂ REQUIREMENT UNDER STANDARD CONDITIONS (SOR)

19	Basin Temperature =	68	°F	Input maximum basin temperature
20	Elevation =	1300	ft above msl	Input basin elevation
21	C _w =	2.0	mg/l	Operating O ₂ conc. of wastewater
22	α =	0.85		Mass transfer correction factor
23	β =	0.95		Saturation factor
24	C _{s20} =	9.09	mg/l	O ₂ saturation conc. at 20 deg Celcius
25	τ =	1.00		Temperature correction factor
26	Ω =	0.95		Altitude correction factor
27	C _s =	8.7	mg/l	O ₂ saturation conc. at field conditions
28	(Standardized) SOR =	34.0	lb O ₂ / hour	

POWER REQUIREMENTS

Unit Model	Aspirator 2HP
Unit Output	3.6 lb O ₂ / hour
Power per Unit	2.0 hp

OXYGEN

SOR	34.0 lb O ₂ / hour
# of Units Required	10
Total Output	36.0 lb O ₂ / hour
Total Oxygen Power	20.0 hp

MIXING

Type of Mixing	Facultative Lagoon
Mixing Requirement	5.0 hp/MG
Mixing Power Required	130.0 hp
# of Units Required	65
Total Mixing Power	130.0 hp

RECOMMENDATIONS

Unit Model	Aspirator 2HP	Number of Units	65
Total Power	130.0	hp	
Basis of Design	Mixing		

NOTES



Aeration Industries International

Cell 1 Design Calculations

Project Name: 0
Project No.: 0

Date 1/0/1900
Prepared By 0
Revision: 0

Design Flow = 146,000 gpd = 552.61 m³/d
Lagoon Water Depth = 9 ft = 2.7 m

1st Cell in Series

Total Lagoon Volume = 36.45 MG = 137963 m³
Total Number of Cells in Series = 1
Cell 1 Volume = 29.70 MG = 112415 m³
HRT in Cell 1 = 203.42 days

Suspended Growth BOD Removal Calculations

Aerated Lagoon Reactors In Series

(Metcalf & Eddy, 4th Ed., p.271)

$$S = S_o / [1 + (k_T / n) * \tau]^n$$

where

S = effluent BOD concentration, mg/l

S_o = influent BOD concentration, mg/l

τ = total retention time, days

T = wastewater temperature, C

k_T = reaction coefficient, days⁻¹

n = number of reactors

$$k_T = k_{20} (\theta^{T-20})$$

where

k₂₀ = reaction coefficient at 20 deg. C = 0.06 days⁻¹

θ = temperature factor = 1.04

REACTORS IN SERIES

Number of Reactors = 1

Min. Lagoon Temperature

T = 10 C
τ = 203.42 days
S_o = 200 mg/l

k_T = 0.04 days⁻¹

S = 22 mg/l

Max. Lagoon Temperature

T = 20 C
τ = 203.42 days
S_o = 200 mg/l

k_T = 0.06 days⁻¹

S = 15 mg/l



Aeration Industries International

Cell 2 Design Calculations

Project Name: 0
Project No.: 0

Date 1/0/1900
Prepared By 0
Revision: 0

Design Flow = 146,000 gpd = 552.61 m3/d
Lagoon Water Depth = 9 ft = 2.7 m

2nd Cell in Series

Total Lagoon Volume = 36.45 MG = 137963 m3
Total Number of Cells in Series = 1
Cell 2 Volume = 6.75 MG = 25548.8 m3
HRT in Cell 2 = 46.23 days

Suspended Growth BOD Removal Calculations

Aerated Lagoon Reactors In Series
(Metcalf & Eddy, 4th Ed., p.271)

$$S = S_o / [1 + (k_T / n) * \tau]^n$$

where
S = effluent BOD concentration, mg/l
S_o = influent BOD concentration, mg/l
τ = total retention time, days
T = wastewater temperature, C
k_T = reaction coefficient, days-1
n = number of reactors

$$k_T = k_{20} (\theta^{T-20})$$

where
k₂₀ = reaction coefficient at 20 deg. C = 0.06 days⁻¹
θ = temperature factor = 1.04

REACTORS IN SERIES

Number of Reactors = 1

Min. Lagoon Temperature

T = 10 C
τ = 46.23 days
So = 22 mg/l

k_T = 0.04 days⁻¹

S = 8 mg/l

Max. Lagoon Temperature

T = 20 C
τ = 46.23 days
So = 15 mg/l

k_T = 0.06 days⁻¹

S = 4 mg/l